



LOS ANGELES COUNTY FIRE DEPARTMENT
PREVENTION BUREAU

344
FIRE FLOW PER-RECORD
4/26/2006
STAGE 2 DROUGHT

FORM 195
01/02

Fire Prevention Engineering
5823 Rickenbacker Road
Commerce, CA 90040-3027
Telephone (323) 890-4125 Fax (323) 890-4129

Information on Fire Flow Availability for Building Permit

For Single Family Dwellings (R-3)

INSTRUCTIONS:

Complete parts I, II (A) when:

Verifying fire flow, fire hydrant location and fire hydrant size.

Complete parts I, II (A), & II (B) when:

For buildings equipped with fire sprinkler systems, and/or private on-site fire hydrants.

PROJECT INFORMATION
(To be Completed by Applicant)

PART I

Building Address: 17009 Brookport St

City or Area: Covina

Nearest Cross Street: Cypress & Lark Ellen

Distance of Nearest Cross Street: _____

Property Owner: Arturo Paz & Irma Valera

Address: 17009 Brookport St Telephone: (626) 332-9670

City: Covina CA 91722

Occupancy (Use of Building): _____ Sprinklered Yes () No ()

Type of Construction: 2 story addition &

Square Footage: _____ Number of Stories: _____

Present Zoning: _____

Date

[Signature]
Signature of Applicant

PART II (A) INFORMATION ON FIRE FLOW AVAILABILITY
(To be completed by Water Purveyor)

The distance from the fire hydrant to the proposed structure is 250' E of 17009
feet via vehicular access. The fire flow services will be rendered from a 8
inch diameter water main. The hydrant is located on NW/CRN - Vogue & Brookport
(Street)
10 (Feet) S (Direction) of BROOKPORT (Nearest Cross - Street)

Under normal operating conditions the fire flow available from this 4x1(2.5) (size)
hydrant is 1710 GPM at 20 PSI residual for 2 hours at 50 PSI Static
PER RECORD 4/26/2006

PART II (B) SPRINKLERED BUILDINGS ONLY

Detector Location:(check one) ☐ Above Grade ☐ Below Grade ☐ Either

Backflow protection required (fire sprinklers/private hydrant): ☐ Yes ☐ No

Type of Protection Required:(check one)

☐ Double Check Detector Assembly ☐ Reduced Pressure Principal Detector Assembly

☐ Other _____ Domestic Meter Size _____

City of Anson
Water Purveyor

George A. Gaytan
Signature

10-2-07
Date

Crew Supervisor
Title

PART III Conditions for Approval by the Building Department
(To be Completed by Building Department)

The building permit may be issued for single family dwellings when the above information is complete and shows that the following minimum requirements are met and the property is not in Fire Zone 4 or the Very High Fire Hazard Severity Zone.

The water system is capable of delivering at least 1250 GPM at 20 PSI for two hours.

The distance from the structure to the fire hydrant does not exceed 450 feet via vehicular access.

The proposed construction must be within 150 feet of a vehicular access roadway that is a minimum of 20 feet wide, paved with concrete or asphalt and does not exceed 15% grade.

APPROVED BY _____

DATE _____

OFFICE _____

This Information is Considered Valid for Twelve Months

Where the water service does not meet the above requirements for approval by the **Building Department, Fire Prevention Division** approval of the site plan will be required before a Building Permit can be issued by the Building Department.